
C1.3 SYSTEM 'C' PERMEABLE PAVING TO TRAFFICKED AREAS (NO INFILTRATION)




TYPICAL CROSS SECTION

SCALE @ A0: 1:10
SCALE @ A2: 1:20

(*) CLAUSE & TABLE REFERENCES REFER TO BS 7533-PART 13

NOTE: FOR PAVED AREAS SUBJECT TO OCCASIONAL HGV LOADING (e.g. EDGE OF ROAD PARKING BAYS) INCREASE THE HYDRAULICALLY BOUND AGGREGATE LAYER THICKNESS TO 200mm

C2.3 SYSTEM 'C' PERMEABLE PAVING TO PEDESTRIAN AREAS (NO INFILTRATION)




TYPICAL SECTION

SCALE @ A0: 1:10
SCALE @ A2: 1:20

C3 GRASSCRETE

C3.1 150mm GRASSCRETE



FOR TYPICAL SUB GRADES, THE FOLLOWING GUIDELINE CAN BE USED FOR SUB-BASE

CBR 4% 150mm Thick
CBR 2-4% 250mm - 200mm Thick
CBR<2% 300mm + Thick

**THE SAND BLINDING LAYER IS INTENDED TO CREATE A UNIFORM SEATING FOR THE GRASSCRETE FORMERS AND TO PREVENT THE LOSS OF SOIL INTO THE SUB-BASE. IT IS NOT INTENDED TO BE A REGULATING LAYER

TYPICAL SECTION

SCALE @ A0: 1:10
SCALE @ A2: 1:20

MAINTENANCE REQUIREMENTS FOR PERMEABLE PAVEMENTS


REGULAR MAINTENANCE
BRUSHING AND VACUUMING (STANDARD COSMETIC SWEEP OVER WHOLE SURFACE). ONCE A YEAR, AFTER AUTUMN LEAF FALL, OR REDUCED FREQUENCY AS REQUIRED, BASED ON SITE-SPECIFIC OBSERVATIONS OF CLOGGING OR MANUFACTURER'S RECOMMENDATIONS - PAY PARTICULAR ATTENTION TO AREAS WHERE WATER RUNS ONTO PERVIOUS SURFACE FROM ADJACENT IMPERMEABLE AREAS AS THIS AREA IS MOST LIKELY TO COLLECT THE MOST SEDIMENT
STABILISE AND MOW CONTRIBUTING AND ADJACENT AREAS. FREQUENCY - AS REQUIRED
REMOVAL OF WEEDS OR MANAGEMENT USING GLYPHOSPATE APPLIED DIRECTLY INTO THE WEEDS BY AN APPLICATOR RATHER THAN SPRAYING. FREQUENCY - AS REQUIRED - ONCE PER YEAR ON LESS FREQUENTLY USED PAVEMENTS

REMEDIAL ACTIONS
REMEDIATE ANY LANDSCAPING WHICH, THROUGH VEGETATION MAINTENANCE OR SOIL SLIP, HAS BEEN RAISED TO WITHIN 50mmOF THE LEVEL OF THE PAVING. FREQUENCY - AS REQUIRED
REMEDIAL WORK TO ANY DEPRESSIONS, RUTTING AND CRACKED OR BROKEN BLOCKS CONSIDERED DETRIMENTAL TO THE STRUCTURAL PERFORMANCE OR A HAZARD TO USERS, AND REPLACEMENT OF LOST JOINTING MATERIAL. FREQUENCY - AS REQUIRED
REHABILITATION OF SURFACE AND UPPER SUBSTRUCTURE BY REMEDIAL SWEEPING. FREQUENCY - EVERY 10 TO 15 YEARS OR AS REQUIRED (IF INFILTRATION PERFORMANCE IS REDUCED DUE TO SIGNIFICANT CLOGGING)

MONITORING
INITIAL INSPECTION: MONTHLY FOR THREE MONTHS AFTER INSTALLATION. INSPECT FOR EVIDENCE OF POOR OPERATION AND/OR WEED GROWTH AND IF REQUIRED, TAKE REMEDIAL ACTION
THREE-MONTHLY, 48 H AFTER LARGE STORMS IN FIRST SIX MONTHS: INSPECT SILT ACCUMULATION RATES AND ESTABLISH APPROPRIATE BRUSHING FREQUENCIES.
MONITOR INSPECTION CHAMBERS ANNUALLY

NOTE:
FOR PERMEABLE PAVED AREAS WITHIN 1.5m OF BUILDING FOUNDATIONS OR 1.5 METRES OF THE SITE BOUNDARY, AN IMPERMEABLE MEMBRANE STRIP 1.5m WIDE SHOULD BE PROVIDED IE. TYPE B1 OR B2 DETAILS WILL APPLY LOCALLY.


D1.1 SOFT LANDSCAPING - EXTENSIVE GREEN ROOF ON DRAINAGE BOARD



TYPICAL DETAIL

SCALE @ A0: 1:10
SCALE @ A2: 1:20

D4.1 GRAVEL FINISH ON DRAINAGE BOARD



TYPICAL DETAIL

SCALE @ A0: 1:10
SCALE @ A2: 1:20

NOTES:
1. DETAILED DESIGN & SPECIFICATION OF BLUE & GREEN ROOF OR PODIUM SYSTEMS BY THE SUPPLIER, SUBJECT TO APPROVAL.
2. ALL MEMBRANES / SHEETS TO BE UV STABILISED & ROT PROOF.
3. A 1000 mm EMERGENCY PARAPET OVERFLOW PIPE SHOULD BE PROVIDED ON ALL BLUE ROOFS.


MAINTENANCE REQUIREMENTS FOR GREEN ROOFS

REGULAR INSPECTIONS. ANNUALLY AND AFTER SEVERE STORMS. INSPECT ALL COMPONENTS INCLUDING SOIL SUBSTRATE, VEGETATION, DRAINS, IRRIGATION SYSTEMS (IF APPLICABLE), MEMBRANES AND ROOF STRUCTURE FOR PROPER OPERATION, INTEGRITY OF WATERPROOFING AND STRUCTURAL STABILITY.
INSPECT SOIL SUBSTRATE FOR EVIDENCE OF EROSION CHANNELS AND IDENTIFY ANY SEDIMENT SOURCES.
INSPECT DRAIN INLETS TO ENSURE UNRESTRICTED RUNOFF FROM THE DRAINAGE LAYER TO THE CONVEYANCE OR ROOF DRAIN SYSTEM
INSPECT UNDERSIDE OF ROOF FOR EVIDENCE OF LEAKAGE.

REGULAR MAINTENANCE
REMOVE DEBRIS AND LITTER TO PREVENT CLOGGING OF INLET DRAINS AND INTERFERENCE WITH PLANT GROWTH. SIX MONTHLY AND ANNUALLY OR AS REQUIRED
DURING ESTABLISHMENT (I.E. YEAR ONE), REPLACE DEAD PLANTS AS REQUIRED. MONTHLY (BUT USUALLY RESPONSIBILITY OF MANUFACTURER)
POST ESTABLISHMENT, REPLACE DEAD PLANTS AS REQUIRED (WHERE > 5% OF COVERAGE). ANNUALLY (IN AUTUMN)
REMOVE FALLEN LEAVES AND DEBRIS FROM DECIDUOUS PLANT FOLIAGE. SIX MONTHLY OR AS REQUIRED
REMOVE NUISANCE AND INVASIVE VEGETATION, INCLUDING WEEDS SIX MONTHLY OR AS REQUIRED MOW GRASSES, PRUNE SHRUBS AND MANAGE OTHER PLANTING
(IF APPROPRIATE) AS REQUIRED - CLIPPINGS SHOULD BE REMOVED AND NOT ALLOWED TO ACCUMULATE. SIX MONTHLY OR AS REQUIRED

REMEDIAL ACTIONS
IF EROSION CHANNELS ARE EVIDENT, THESE SHOULD BE STABILISED WITH EXTRA SOIL SUBSTRATE SIMILAR TO THE ORIGINAL MATERIAL, AND SOURCES OF EROSION DAMAGE SHOULD BE IDENTIFIED AND CONTROLLED. FREQUENCY AS REQUIRED.
IF DRAIN INLET HAS SETTLED, CRACKED OR MOVED, INVESTIGATE AND REPAIR AS APPROPRIATE. FREQUENCY AS REQUIRED.


CX.1 TYPICAL PERMEABLE PAVING ROOF RAINWATER PIPE INLET, APPLICABLE TO SYSTEMS 'A', 'B' & 'C.'



TYPICAL SECTION

SCALE @ A0: 1:10
SCALE @ A2: 1:20

CX.2 TYPICAL PERMEABLE PAVING OUTLET DETAIL, APPLICABLE TO SYSTEMS 'B' & 'C.'



TYPICAL SECTION

SCALE @ A0: 1:10
SCALE @ A2: 1:20

NOTE:
FOR PERMEABLE PAVEMENT WITH ATTENUATION STORAGE USE A MANHOLE WITH A HYDROBRAKE FLOW CONTROL DEVICE OR SIMILAR

PERMEABLE PAVING TYPICAL DETAILS

NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL ENGINEERS & ARCHITECTS DRAWINGS.FIGURED DIMENSIONS ONLY (NOT SCALING) TO BE USED. WHERE A CONFLICT OF INFORMATION EXISTS OR IF IN ANY DOUBT - ASK.
2. CONSULTANTS TO BE INFORMED IMMEDIATELY OF ANY DISCREPANCIES BEFORE WORK PROCEEDS.

ISSUE	DATE	DESCRIPTION	DRN / CHKD
PL2	08.07.26	ISSUED FOR PLANNING	US / SH
PL1	08.08.25	ISSUED FOR PLANNING	SP / SH

DRAWING STAGE
PLANNING

BM BARRETT MAHONY
Dublin Office:
Sandwith House, 52-54 Lower Sandwith Street, Dublin 2, Ireland.
Tel: (01) 677 3200 Fax: (01) 677 3164
London Office:
5th Floor, Mill House, 8 Mill Street, London SE1 2BA, United Kingdom
Tel: (0044) 20 3750 3530
Consulting Engineers, Civil. Structural . Project Management.E-mail: bmce@bmce.ie Web: www.bmce.ie

CLIENT
SEATTLE CONSTRUCTION LTD.

PROJECT TITLE
KILWOGHAN WOODS, CELBRIDGE, CO KILDARE

BM PROJECT No.
24.283

MODEL REFERENCE
-

MODEL REV.
0

SUITABILITY
S0

DRAWING TITLE
SUDS DETAILS
PERMEABLE PAVING AND GREEN ROOF

DRAWING No.
KWW-BMD-00-XX-DR-C-14310

ISSUE
PL2